


ITEM	DESCRIPTION	QTY	REMARKS
1	WOODEN STRUT POLE	1	10m LONG WITH TOP 140mm (MIN)
2	POLE BRACKET	2	50x50mm FLAT BAR – GALVANISED
3	BASE PLATE	1	300x300x6mm GMS
4	BARBED WIRE	20m	3.25mm (MIN.)
5	STAPLES	30	3x32mm HOT DIPPED GALVANISED
6	BOLTS & NUTS	3	M16x150mm GALVANISED
7	CUT & CROSOTIED	1	M16x150mm GALVANISED
8	FLAT WASHER	6	M16 GALVANISED

NOTES:

ELECTRICITY CONTROL BOARD



ELECTRICITY CONTROL BOARD
NAMIBIA

Box 2923
Windhoek
NAMIBIA

Tel: (061) 374300
Fax: (061) 374305

DRAWING TITLE

LOW VOLTAGE AERIAL BUNDLED
CONDUCTOR DISTRIBUTION: STAY
ASSEMBLY

DESIGNED: A.K	DRAWN: J.W.S	REV: 01-2001
DRAWING No: STD-LVABC-16		SCALE: N.T.S

ERROR: syntaxerror
OFFENDING COMMAND: --nostringval--

STACK:

/Title
()
/Subject
(D:20100127105557+02'00')
/ModDate
()
/Keywords
(PDFCreator Version 0.9.5)
/Creator
(D:20100127105557+02'00')
/CreationDate
(johnny)
/Author
-mark-