



COPYRIGHT © 2009 EMCON
 ALL RIGHTS RESERVED. NO PART OF THIS PUBLICATION MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE PERMISSION IN WRITING FROM EMCON.



ITEM	DESCRIPTION	QTY	REMARKS
1	POLE TOP MAKE OFF	1	BT 472-6
2	GUY GRIP	4	GSDE 472
3	INSULATOR	4	GUJLVAN 0922
4	STAY WIRE	40m	7/4.00 STAY WIRE
5	DOUBLE WRAP GUY GRIP	1	DWGS FOR 7/4.00
6	STAY ROD WITH THIMBLE	1	2400mm LONG X 16mm ϕ
7	BASE PLATE	1	450X450X6mm GMS
8	EYE BOLT WITH THIMBLE	1	M20X250
9	POLE CAP		
10	ANGER PLATE		

NOTES:
 1. USED ONLY WHERE MV POLE STAY ASSEMBLY WILL NOT FIT OR AS INSTRUCTED.

ELECTRICITY CONTROL BOARD



Box 2923
 Windhoek
 NAMIBIA
 Tel: (061) 374300
 Fax: (061) 374305

**MEDIUM VOLTAGE BARE OVERHEAD DISTRIBUTION
 MV FLY STAY ASSEMBLY**

DESIGNED: A.K	DRAWN: J.W.S	REV: 01-2001
DRAWING No: STD-MVAE-11KV-17	SCALE: N.T.S	

ERROR: syntaxerror
OFFENDING COMMAND: --nostringval--

STACK:

/Title
()
/Subject
(D:20100127122812+02'00')
/ModDate
()
/Keywords
(PDFCreator Version 0.9.5)
/Creator
(D:20100127122812+02'00')
/CreationDate
(johnny)
/Author
-mark-